

TECHNICAL DATA SHEET



WATER MIST FIRE EXTINGUISHER 6LTR

WATER MIST 6 Ltr Fire Extinguishers applicable on Class A, B, kitchen Fire and electrically operated fires.

Brief description: Lightweight, durable, and compliant with safety standards. Water Mist type Fire Extinguishers with nominal charge of 6 ltr ($\pm 5\%$ by volume). Constructed of M.S body and brass forged discharge Valve.

1. GENERAL DATA :-

Manufacturer	Palladium Safety Solutions Pvt. Ltd.
Trade Mark/Brand	“PALEX”
BIS Standard Code	IS 15683:2018
Type	Portable Fire Extinguisher Stored Pressure Type



2. PERFORMANCE DATA :-

Capacity	6LTR
Fire Rating	2A, 55B, 75F (Class “A” – Solid Fuel, Class “B” – Liquid Fuel, Class “F” – Fatty Oil and Eatable Oil.)
Performance requirements	Min. Effective discharge time : 13 Sec. (Actual : 55 Sec. Approx.) Min. Bulk range of discharge : 2 Mtr. (Actual : 3.5 Mtr. Approx.) Min. Percentage of discharge : 95% (Actual : 97% Approx.)
Working Temperature	(+) 5°C To (+) 60°C
Service Pressure	15 BAR
Maximum Service Pressure	17 BAR

3. MATERIAL OF CONSTRUCTION :-

Body	MS Sheet (Low Carbon Welded Sheet Having max. of 0.25% C, 0.05% P and 0.05% S (IS 513))
Extinguishing Media	Distilled Water + 6% Foam to 4PPM
Neck Ring	MS pipe, Female Threaded (Filling Dia – 29mm)
Valve	Brass – Male Threaded, Squeeze Grip Type
Syphon Tube	Aluminium/PVC
Strainer	Plastic
Hose Pipe	PVC Braided (500mm ± 10 mm)
Pressure Gauge/Indicator	As per IS 15683:2018
Discharge Nozzle	Brass (Mist Type)

4. QUALITY TEST :-

Hydro Pressure Test (Pt)	35 bar (3.5 MPa) Hold for 1 min.
Min. Burst pressure (Pb) for body	55 bar (5.5 MPa) Hold for 1 min.
Leakage test	Inverted glass jar / Soap solution
Partial discharge	The second pressure or weight shall not be less than 75% of the first after interruption of the Discharge

5. DIMENSIONS :-

Diameter	145mm $\pm$ 2mm
Height	455mm $\pm$ 2 mm
Thickness	Made up from 1.2mm Thick Sheet
Full/Gross Weight of Extinguisher	8.8KG $\pm$ 2% (Approx.)

6. Anti – Corrosion Treatment :-

The Extinguisher Undergo a 7-tank Anti-Corrosion Process, Followed by an Epoxy Powder Coating, Which is no Less than 50 Microns in Thickness.

7. MISCELLENEOUS :-

Inspection & testing	As per approved QAP
Marking	As per IS 15683:2018
Approvals	BIS (BUREAU OF INDIAN STANDARD)
Maintenance, care and refilling	As per IS 2190

8. PACKING :-

Box Type	Corrugated Boxes
Dimension	175mm X 175mm X 520mm

9. IN BOX ACCESSORIES:-

Wall Mounting Bracket	1 Nos
Fire Extinguisher	1 No (Fully Assembled)

PALLADIUM SAFETY SOLUTIONS PVT. LTD.

An ISO 9001 : 2015 Certified Company

Email: customercare@palladiumss.com Web: www.palladiumss.com

DELHI I GURUGRAM I CHENNAI